



DECLARATION OF SALT FOG RESISTANCE

Mr. Jesús Valcárcel Gomariz, in his capacity as CHEMIST representative of the company DECOPROYEC SUBERTRES S.L.U., with CIF: B-02528978 and registered office at Camporroso Industrial Estate, C/ Guadalajara 12, 02520 CHINCHILLA DE MONTEARAGÓN (ALBACETE),

DECLARES

That the product SPRAYED CORK DECOPROYEC, manufactured at our production center located at Camporroso Industrial Estate, C/ Guadalajara 12, 02520 CHINCHILLA DE MONTEARAGÓN (ALBACETE), has been subjected to the test of "Resistance and behavior in a saline environment" according to the standard UNE-EN ISO 9227:2006, which consists of subjecting a series of standardized samples to 1000 hours of continuous exposure in a salt fog chamber equipped with sprayers of a 50 g/l sodium chloride solution at a 20° angle with the vertical of the salt fog. The result of this test has been satisfactory and positive as indicated in the report IT130117 conducted by the officially accredited laboratory AIDICO, highlighting in the conclusions of the report that after 1000 hours of exposure to salt fog no visible change or adhesion defect between the sprayed cork and the support on which it was applied has occurred.

In Chinchilla de Montearagón on the 21st of November 2013

Signed: Jesús Valcárcel Gomariz.

Chemist

